

**DISPLACEMENT MEASURING SYSTEMS AND DEVICES USED IN MATERIAL TESTING MACHINES IN ACCORDANCE WITH ASTM-E2309/E2309M-20.**

**CUSTOMER**

COMPANY: [REDACTED]  
ADDRESS: [REDACTED]  
CITY/PROVINCE: [REDACTED]

**CALIBRATION INFORMATION**

PURCHASE ORDER NUMBER: [REDACTED]  
CERTIFICATE NUMBER: [REDACTED]  
CERTIFICATE ISSUED: March 8, 2025  
CALIBRATION DATE: March 7, 2025  
REQUESTED DUE DATE: March 7, 2026  
SYSTEM LOCATION: [REDACTED]  
MANUFACTURER: [REDACTED]  
MODEL: [REDACTED]  
SERIAL NUMBER: [REDACTED]  
ASSET NUMBER: Displacement  
INDICATOR RESOLUTION: 0.001 in  
TEMPERATURE / RELATIVE HUMIDITY: 21.26°C/30.23%  
CALIBRATION TECHNICIAN: Saverio Amerato

**CALIBRATION IS VALID FOR THE SCALE(S), ITEMS AND RESULTS SHOWN AND HAS BEEN FOUND TO BE WITHIN TOLERANCE UNLESS OTHERWISE NOTED.**

**STANDARDS USED**

FILE	SERIAL #	MFG	CAL DATE	DUE DATE	CERT BY	CERT #	CAPACITY	UNC
TH 003	S2450843/S2310657	Vaisala	02/02/24	02/02/26	Transcat	33-Q3F0N-20-1	Deg/%RH	0.5/0.14 Deg/%RH
DIM 006	0008872	Mitutoyo	10/03/24	10/03/25	Affri Inc.	AffriUS_0008872-DIM006_ASMEB89_031024	12 in	0.0014 in

**TRACEABILITY, UNCERTAINTY AND DECISION RULE STATEMENTS**

The expanded uncertainties shown above use a confidence level of 95% and a coverage factor of  $k = 2$ . Expanded uncertainties are valid from 18°C to 28°C. ALL REFERENCE STANDARDS USED FOR VERIFICATION ARE TRACEABLE TO NIST OR ACCREDIA. Services comply with PO requirements. Affri uses a binary decision rule of pass or fail where tolerance limit equals acceptance limits without considering uncertainty. Uncertainty and measured results are provided for the user to consider their own risk.

**COMMENTS**

Preventative maintenance was performed.



**CUSTOMER**

COMPANY: [REDACTED]

**CALIBRATION INFORMATION**

CERTIFICATE NUMBER: [REDACTED]  
 CERTIFICATE ISSUED: March 8, 2025  
 CALIBRATION DATE: March 7, 2025  
 REQUESTED DUE DATE: March 7, 2026  
 MODEL: [REDACTED]  
 SERIAL NUMBER: [REDACTED]

**AS FOUND:**

REF STD USED	REF. STD. READING (in)	DUT READING RUN #1 (in)	DIRECTION:		COMPRESSION	
			DUT ERROR RUN #1 (in)	DUT ERROR RUN #1 (%RD)	ASTM CLASS	
	0.000	0.000	0.000			
DIM 006	0.500	0.500	0.000	0.00%	A	
	1.000	1.002	0.002	0.20%	B	
	2.000	1.998	-0.002	-0.10%	B	
	3.000	3.002	0.002	0.07%	B	
	4.000	4.002	0.002	0.05%	B	
	5.000	5.002	0.002	0.04%	B	

Resolution (in)	ASTM CLASS
0.001	A


Overall ASTM Class
B

**AS LEFT:**

REF STD USED	REF. STD. READING (in)	DUT READING RUN #1 (in)	DUT READING RUN #2 (in)	DUT ERROR RUN #1 (in)	DUT ERROR RUN #2 (in)	DUT ERROR RUN #1 (%RD)	DUT ERROR RUN #2 (%RD)	DUT REPEAT. (in)	DUT REPEAT. (%RD)	DIRECTION:		COMPRESSION	
										STD. UNCER. DUE TO REPEAT. (%RD)	STD. UNCER. DUE TO CAL LAB (%RD)	MEASURE. UNCER. (K=2) (%RD)	ASTM CLASS
	0.000	0.000	0.000	0.000	0.000								
DIM 006	0.500	0.500	0.500	0.000	0.000	0.00%	0.00%	0	0.00%	0.17%	0.17%	0.50%	A
	1.000	1.002	1.001	0.002	0.001	0.20%	0.10%	0.001	0.10%	0.08%	0.09%	0.25%	B
	2.000	1.998	2.000	-0.002	0.000	-0.10%	0.00%	0.002	0.10%	0.04%	0.04%	0.13%	B
	3.000	3.002	3.001	0.002	0.001	0.07%	0.03%	0.001	0.03%	0.03%	0.03%	0.09%	B
	4.000	4.002	4.001	0.002	0.001	0.05%	0.03%	0.001	0.02%	0.02%	0.02%	0.06%	B
	5.000	5.002	5.001	0.002	0.001	0.04%	0.02%	0.001	0.02%	0.02%	0.02%	0.05%	B

**COMMENTS**

Preventative maintenance was performed.





**CUSTOMER**

COMPANY: [REDACTED]

**CALIBRATION INFORMATION**

CERTIFICATE NUMBER: [REDACTED]  
 CERTIFICATE ISSUED: March 8, 2025  
 CALIBRATION DATE: March 7, 2025  
 REQUESTED DUE DATE: March 7, 2026  
 MODEL: [REDACTED]  
 SERIAL NUMBER: [REDACTED]



SAMPLE

[REDACTED]



**CUSTOMER**

COMPANY: [REDACTED]

**CALIBRATION INFORMATION**

CERTIFICATE NUMBER: [REDACTED]  
 CERTIFICATE ISSUED: March 8, 2025  
 CALIBRATION DATE: March 7, 2025  
 REQUESTED DUE DATE: March 7, 2026  
 MODEL: [REDACTED]  
 SERIAL NUMBER: [REDACTED]

**AS FOUND:**

REF STD USED	REF. STD. READING (in)	DUT READING RUN #1 (in)	DIRECTION:		TENSION	
			DUT ERROR RUN #1 (in)	DUT ERROR RUN #1 (%RD)	ASTM CLASS	
	0.000	0.000	0.000			
DIM 006	0.500	0.500	0.000	0.00%	A	
	1.000	0.999	-0.001	-0.10%	B	
	2.000	2.000	0.000	0.00%	A	
	3.000	3.000	0.000	0.00%	A	
	4.000	4.001	0.001	0.03%	B	
	5.000	5.001	0.001	0.02%	B	

Resolution (in)	ASTM CLASS
0.001	A


Overall ASTM Class
B

**AS LEFT:**

REF STD USED	REF. STD. READING (in)	DUT READING RUN #1 (in)	DUT READING RUN #2 (in)	DUT ERROR RUN #1 (in)	DUT ERROR RUN #2 (in)	DUT ERROR RUN #1 (%RD)	DUT ERROR RUN #2 (%RD)	DUT REPEAT. (in)	DUT REPEAT. (%RD)	STD. UNCER. DUE TO REPEAT. (%RD)	STD. UNCER. DUE TO CAL LAB (%RD)	DIRECTION:		TENSION	
												MEASURE. UNCER. (K=2) (%RD)	ASTM CLASS		
	0.000	0.000	0.000	0.000	0.000										
DIM 006	0.500	0.500	0.500	0.000	0.000	0.00%	0.00%	0.000	0.00%	0.06%	0.17%	0.40%		A	
	1.000	1.000	1.000	0.000	0.000	0.00%	0.00%	0.000	0.00%	0.03%	0.09%	0.20%		A	
	2.000	2.000	2.001	0.000	0.001	0.00%	0.05%	0.001	0.05%	0.02%	0.04%	0.10%		A	
	3.000	3.001	3.001	0.001	0.001	0.03%	0.03%	0.000	0.00%	0.01%	0.03%	0.07%		A	
	4.000	4.001	4.001	0.001	0.001	0.03%	0.03%	0.000	0.00%	0.01%	0.02%	0.05%		B	
	5.000	5.001	5.001	0.001	0.001	0.02%	0.02%	0.000	0.00%	0.01%	0.02%	0.04%		B	

**COMMENTS**

Preventative maintenance was performed.





**CUSTOMER**

COMPANY: [REDACTED]

**CALIBRATION INFORMATION**

CERTIFICATE NUMBER: [REDACTED]  
 CERTIFICATE ISSUED: March 8, 2025  
 CALIBRATION DATE: March 7, 2025  
 REQUESTED DUE DATE: March 7, 2026  
 MODEL: [REDACTED]  
 SERIAL NUMBER: [REDACTED]

